

**SECTION 174.** Table 1001.5-A of Volume VI of the Building and Safety Code is added to read as follows:  
**TABLE 1001.5-A REQUIRED SERVICE AND CERTIFICATION INTERVALS**

	QUARTERLY	SEMI ANNUAL	ANNUAL	EVERY 5 YEARS
<b>ENGINEERED FIXED EXTINGUISHING SYSTEMS (1 OR 5)</b>				
Dry Chemical System		X		
Carbon Dioxide System		X		
Halogenated System		X		
Steam System		X		
High Expansion Foam System		X		
Foam Extinguishing System		X		
Liquid Agent Extinguishing System		X		
<b>STANDPIPE SYSTEMS (1 or 5)</b>				
Class I Standpipe System			X	X
Class II Standpipe System			X	X
Class III Standpipe System			X	X
Combined Standpipe System			X	X
<b>AUTOMATIC FIRE SPRINKLER (1 or 5)</b>				
Wet Pipe Sprinkler System			X	X
Dry Pipe Sprinkler System			X	X
Deluge Sprinkler System			X	X
Dry Pipe Pre-Action Sprinkler System			X	X
Fixed Water Spray System			X	X
Deluge Foam Water Spray Sprinkler System			X	X
Foam Water System			X	X
<b>AUTOMATIC FIRE ALARM SYSTEM (2 or 7)</b>				
Automatic Fire Alarm System			X	
Central Station Communicator Panels	X		X	
Single Station Hardwired Smoke Detectors (R-1 Occupancy) (6)			X	
<b>MISCELLANEOUS</b>				
Fire Extinguishers (5)			X	
Smoke Control System (3 or 7)	X			
Emergency Battery Back-Up System (2 or 7)			X	
Emergency Generators (2 or 7)			X	
Fire Doors (4 or 7)			X	
Fire Escape Ladders (4 or 7)			X	

1. Must be performed by a State Licensed Fire Protection Contractor (C-16)
2. Must be performed by a State Licensed Electrical Contractor (C-10)
3. Must be performed by a State Licensed Refrigeration Contractor (C-38)
4. May be performed by owner
5. Must be licensed by State Fire Marshal
6. For 25 or less units, qualified owner may perform test
7. Must be performed by a State Licensed General Contractor (B)